

クリーンパーク折居 維持管理記録簿

平成 30年 9月

測定項目	1号炉				2号炉										
	炉出口温度	ろ過式集じん器入口温度	CO濃度(煙突)	排ガス冷却設備ばい塵除去 (スートブロワ)	炉出口温度	ろ過式集じん器入口温度	CO濃度(煙突)	排ガス冷却設備ばい塵除去 (スートブロワ)							
									管理値	800℃以上	200℃以下	30ppm以下	800℃以上	200℃以下	30ppm以下
									単位	℃	℃	ppm	℃	℃	ppm
1	912	169	5	○	919	168	6	○							
2	911	169	7	○	910	169	7	○							
3	920	169	6	○	915	169	5	○							
4					913	171	9	○							
5															
6															
7															
8	929	172	9	○											
9	928	168	10	○	912	172	6	○							
10	922	168	9	○	915	168	10	○							
11	923	168	9	○	912	168	8	○							
12	913	168	8	○	915	168	10	○							
13	918	168	6	○	917	167	5	○							
14	924	168	6	○	931	167	10	○							
15	922	168	4	○	919	168	4	○							
16	922	169	6	○	926	168	4	○							
17	912	170	7	○	913	168	4	○							
18	920	169	6	○	924	168	7	○							
19	922	168	7	○	931	167	4	○							
20	923	167	8	○	932	166	4	○							
21	919	168	8	○	923	167	4	○							
22	921	168	6	○	924	168	6	○							
23	918	167	6	○	924	167	4	○							
24	920	167	8	○	926	167	6	○							
25	922	168	10	○	924	167	5	○							
26	929	167	5	○	928	167	4	○							
27	932	167	8	○	931	167	6	○							
28	929	166	7	○	930	167	5	○							
29					941	168	6	○							
30					945	168	9	○							
月平均	921	168	7	—	923	168	6	—							

※ 一酸化炭素濃度は、4時間平均値で管理しています。